

EMBASSY OF ARGENTINA IN THE UNITED STATES OF AMERICA
UPS BATTERY REPLACEMENT

REQUEST FOR PROPOSALS – TECHNICAL SPECIFICATIONS

SELECTION PROCESS		
TYPE	DIRECT CONTRACT by SIMPLIFIED PROCEDURE N° 22	Period: 2023
CLASS	N/A	
MODE	N/A	
File No. 42	Period: 2023	
Purpose of the Contract:		
To hire a company to do the battery Installation, Removal & Disposal, during normal hours for one APC Smart-UPS 3 kVA, SURTA 3000XL, Serial #QS1404141332 for the Embassy of the Argentine Republic in the United States of America .		

PRESENTATION OF OFFERS

Address	Timeline and Schedule
Embassy of Argentina 1600 New Hampshire Avenue NW, Washington D.C. 20009 <i>or by email:</i> administracion@embassyofargentina.us	Monday through Friday from 10 am to 4pm until February 9, 2023 at 3:30 pm

OPENING OF OFFERS

Location/Address	Date and Time
Embassy of Argentina 1600 New Hampshire Avenue NW, Washington D.C. 20009, USA	February 9, 2023 4:00 pm

IMPORTANT: Offers received after the designated date and time will not be considered, regardless of reasons for the delay.

**EMBASSY OF ARGENTINA IN THE UNITED STATES OF AMERICA
UPS BATTERY REPLACEMENT**

II. TECHNICAL SPECIFICATIONS

1. PURPOSE

The purpose of this request is to do the battery Installation, Removal & Disposal, during normal hours for an APC Smart-UPS 3 kVA, SURTA 3000XL, Serial #QS1404141332 for the Embassy of the Argentine Republic in the United States of America located at 1600 New Hampshire Ave, N.W., Washington DC, in accordance with the technical specifications and other documents governing this request for proposals.

2. SCOPE OF WORK

The scope includes the supply of labor and all the necessary elements for the service to be complete and adequate for its purpose, in accordance with the trade's rules, the technical specifications and the documentation governing this invitation to bid. If the technical specifications or bidding documents do not list all the necessary work to achieve the result or the necessary elements to perform them, the Contractor must perform and/or provide them, without the right to demand any additional payment.

The work shall be complete, comply with the local rules and regulations in force, all necessary insurance and conform to the trade's rules according to the purpose for which it is to be performed.

3. TERM

The term for the execution of the works detailed in this contract is THIRTY (30) DAYS counted from the day after the Purchase Order is received, subject to manufacturer lead time.

4. INSURANCE

The Co-contractor must obtain all insurances related to labor risks, third party and property damage prior to the commencement of the work.

5. CLEANING

The Co-contractor must maintain daily cleanliness at the site, including the final disposal of waste and debris generated by the execution of the works.

6. GUARANTEE

The Co-contractor must guarantee the works for SIXTY (60) days for labor, and ONE (1) year for the batteries from the day after the Final Acceptance.

7. DESCRIPTION OF WORK

This items includes the following tasks:

- Batteries must be hermetic and require no maintenance.

EMBASSY OF ARGENTINA IN THE UNITED STATES OF AMERICA
UPS BATTERY REPLACEMENT

- Its nominal voltage and current values must be equivalent to those existing in the uninterruptible power unit.
- All batteries must be of the same type, same manufacturer, same age and capacity.
- It is required to review the internal electrical connections for the batteries, which are in correct conditions for their reconnection, if not, they must be conditioned or repaired.

**EMBASSY OF ARGENTINA IN THE UNITED STATES OF AMERICA
UPS BATTERY REPLACEMENT**

ANNEX A

QUOTATION FORM

LINE	DESCRIPTION	QUANTITY	UNIT	TOTAL [USD]
1	Provision and installation of VRLA Sealed Lead Acid Battery for APC Smart-UPS 3 kVA, SURTA 3000XL Serial #QS1404141332 Dims: 3.54"x2.76"x4.13" Voltage: 12.00000 Warranty: 1 Year Unit Weight: 3.97000 AH/Watts: 5.10000	1	gl	
2	Battery Installation, Removal & Disposal, Normal Hours for APC Smart-UPS 3 kVA Serial #QS1404141332			
4	Shipping, Freight, Delivery and Handling Charges for APC Smart-UPS 3 kVA Serial #QS1404141332 for the Embassy of the Argentine Republic in the United States of America, located at 1600 New Hampshire Ave, N.W., Washington DC, in a whole in accordance with the technical specifications and other documents that govern the Tender.			

Prices must not include taxes charges. -

U.S. DOLLARS (USD).....

.....

Washington,DC.....of February, 2023.

.....

Signature, clarification and stamp
of the Representation's officer

EMBASSY OF ARGENTINA IN THE UNITED STATES OF AMERICA
UPS BATTERY REPLACEMENT

TAX EXEMPTION CARD FOR THE
ARGENTINE EMBASSY TO THE UNITED STATES OF AMERICA

★ UNITED STATES DEPARTMENT OF STATE ★



MISSION TAX EXEMPTION
OFFICIAL PURCHASES ONLY

Mission:
ARGENTINA

Name:
**MAGGIORA,
GUSTAVO ALEJANDRO**

PID#: **3158-3263-50** Expires: **01/31/2025**
DOB: **12/21/1965** Sex: **M**

EXEMPT FROM TAXES IMPOSED
ON ALL PURCHASES,
INCLUDING HOTEL STAYS &
RESTAURANT MEALS




This card authorizes the mission to receive
nationwide exemption from:

**EXEMPT FROM TAXES IMPOSED ON ALL
PURCHASES, INCLUDING HOTEL STAYS &
RESTAURANT MEALS**

Not valid for vehicle purchases. Exemptions may only be authorized if
payment is made with an official check or credit card bearing the name of
the Mission. The validity of this card/privilege may be confirmed at [https://
egov.ofm.state.gov/tecv](https://egov.ofm.state.gov/tecv). For questions, please contact (202) 895-3500 ext. 2
(M-F 8:00AM – 5:00PM ET) or visit www.state.gov/ofm/tax. This card is the
property of the U.S. Department of State.

2000342179 AF9807F64D



123
802